



**South Jersey  
Water Test, LLC**

4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwaterest.com  
NJ DEP Certified Lab #08006

## Lafayette-Pershing School

237 Shell Road  
Carneys Point, NJ 08069

### Results of Lead Analysis

Date & Time Sampled: 04/14/2017 09:55 - 10:44

Date & Time Analyzed: 04/25/2017 11:53 - 16:02

Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
LP-B-1001	3.97	15.5
LP-F-1002	3.46	15.5
LP-WF-1005	<2.00	15.5
LP-F-1003	17.0	15.5
LP-SP-1004	50.3	15.5
LP-B-1007	<2.00	15.5
LP-B-1006	2.67	15.5
LP-F-1008	2.60	15.5
LP-F-1009	8.80	15.5
LP-F-1010	10.0	15.5
LP-B-1011	9.69	15.5
LP-WF-1012	<2.00	15.5
LP-WF-1013	3.09	15.5
LP-B-1014	<2.00	15.5
LP-B-1016	21.4	15.5
LP-B-1015	<2.00	15.5
LP-B-1021	4.24	15.5
LP-B-1019	<2.00	15.5
LP-B-1018	2.88	15.5

Units - ug/L = ppb



**South Jersey  
Water Test, LLC**  
4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwatertest.com  
NJ DEP Certified Lab #08006

## Lafayette-Pershing School

237 Shell Road  
Carneys Point, NJ 08069

### Results of Lead Analysis

Date & Time Sampled: 04/14/2017 09:55 - 10:44

Date & Time Analyzed: 04/25/2017 11:53 - 16:02


Sample Location	Sample Result	Action Level
LP-B-1020	3.90	15.5
LP-B-1023	2.26	15.5
LP-B-1022	14.0	15.5
LP-B-1025	<2.00	15.5
LP-B-1024	<2.00	15.5
LP-B-1027	24.0	15.5
LP-B-1026	<2.00	15.5
LP-B-1029	<2.00	15.5
LP-B-1028	<2.00	15.5
LP-B-1030	<2.00	15.5
LP-B-1031	<2.00	15.5
LP-B-1017	16.0	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.

  
Mark J. Riether, Laboratory Director

5/5/17  
Date



**South Jersey  
Water Test, LLC**  
4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwaterfest.com  
NJ DEP Certified Lab #08006

## Field Street School

144 Field Street  
Carneys Point, NJ 08069

### Results of Lead Analysis

Date & Time Sampled: 04/14/2017 12:20 - 13:00

Date & Time Analyzed: 04/25/2017 16:08 - 16:43

Date & Time Analyzed: 04/26/2017 10:28 - 12:58

Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
FS-F-1014	<2.00	15.5
FS-F-1015	<2.00	15.5
FS-SP-1016	66.0	15.5
FS-F-1023	2.26	15.5
FS-F-1013	<2.00	15.5
FS-F1012	2.58	15.5
FS-F-1011	6.30	15.5
FS-WF-1017	<2.00	15.5
FS-WF-1021	<2.00	15.5
FS-WF-1022	<2.00	15.5
FS-F-1020	2.25	15.5
FS-WF-1001	<2.00	15.5
FS-WF-1002	<2.00	15.5
FS-F-1003	<2.00	15.5
FS-B-1004	2.76	15.5
FS-WF-1005	<2.00	15.5
FS-WF-1006	<2.00	15.5
FS-WF-1007	<2.00	15.5
FS-WF-1008	<2.00	15.5

Units - ug/L = ppb



**South Jersey  
Water Test, LLC**  
4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwatertest.com  
NJ DEP Certified Lab #08006

## Field Street School

144 Field Street  
Carneys Point, NJ 08069

### Results of Lead Analysis

Date & Time Sampled: 04/14/2017 12:20 - 13:00

Date & Time Analyzed: 04/25/2017 16:08 - 16:43

Date & Time Analyzed: 04/26/2017 10:28 - 12:58


Sample Location	Sample Result	Action Level
FS-B-1009	<2.00	15.5
FS-B-1010	<2.00	15.5
FS-WF-1019	<2.00	15.5
FS-WF-1018	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.

  
Mark J. Riether, Laboratory Director

  
Date



**South Jersey  
Water Test, LLC**  
4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwaterfest.com  
NJ DEP Certified Lab #08006

## Paul W. Carleton School

251 Maple Avenue  
Penns Grove, NJ 08069

### Results of Lead Analysis

Date & Time Sampled: 04/14/2017 10:55 - 11:16

Date & Time Analyzed: 04/24/2017 14:10 - 15:58


Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
CS-WF-1001	<2.00	15.5
CS-F-1002	32.3	15.5
CS-F-1003	2.04	15.5
CS-SP-1004	17.8	15.5
CS-WF-1007	<2.00	15.5
CS-F-1008	2.01	15.5
CS-WF-1009	<2.00	15.5
CS-WF-2003	2.30	15.5
CS-WF-2002	<2.00	15.5
CS-WF-2001	<2.00	15.5
CS-WF-1006	<2.00	15.5
CS-WF-1005	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.

  
Mark J. Riether, Laboratory Director

5/5/17  
Date



**South Jersey  
Water Test, LLC**  
4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwatertest.com  
NJ DEP Certified Lab #08006

## Penns Grove Middle School

351 Maple Avenue  
Penns Grove, NJ 08069

### Results of Lead Analysis

Date & Time Sampled: 04/14/2017 11:25 - 12:02

Date & Time Analyzed: 04/24/2017 16:04 - 16:43

Date & Time Analyzed: 04/25/2017 10:13 - 11:30


Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
MS-WF-1008	<2.00	15.5
MS-F-1006	5.29	15.5
MS-SP-1007	3.06	15.5
MS-F-1002	6.64	15.5
MS-F-1005	11.2	15.5
MS-F-1003	<2.00	15.5
MS-F-1004	2.66	15.5
MS-WF-1009	<2.00	15.5
MS-WF-1011	<2.00	15.5
MS-WF-1001	<2.00	15.5
MS-WF-2001	<2.00	15.5
MS-WF-2002	<2.00	15.5
MS-WF-2003	<2.00	15.5
MS-WF-2004	<2.00	15.5
MS-WF-3002	<2.00	15.5
MS-WF-3001	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.

  
Mark J. Riether, Laboratory Director

  
Date

**CHAIN OF CUSTODY RECORD**

**Customer:** Pennsgrove Carneys Point Regional School District  
**Contact:** Timothy Brunetta  
**Address:** 334 Harding Highway  
 Carneys Point, NJ 08069  
**Phone:** **Fax:**  
**Office:** (856) 299-6300 x 3044

**South Jersey Water Test, LLC**  
 4077 South Black Horse Pike  
 Williamstown, NJ 08094  
 Phone: 856-875-3506 Fax: 856-875-3507  
 www.sjwatertest.com  
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
PG3839	MS - Field Blank	4/14/17	1125	D	1 x 250	HNO3*	First Draw Lead	
PG3840	- WF-1008		1127	D	1 x 250	HNO3*	First Draw Lead	
PG3841	F-1006		1130	D	1 x 250	HNO3*	First Draw Lead	
PG3842	SP-1007		1131	D	1 x 250	HNO3*	First Draw Lead	
PG3843	F-1002		1133	D	1 x 250	HNO3*	First Draw Lead	
PG3844	F-1005		1135	D	1 x 250	HNO3*	First Draw Lead	
PG3845	F-1003		1136	D	1 x 250	HNO3*	First Draw Lead	
PG3846	F-1004		1137	D	1 x 250	HNO3*	First Draw Lead	
PG3847	wf-1009		1139	D	1 x 250	HNO3*	First Draw Lead	
PG3848	wf-1011		1145	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWSURFACE WATER WW/WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format <input type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp °C Properly Preserved Yes No
---	--	--	---

Sampled by: Justin Mille

Sampled by/Relinquished by: (Signature) <u>Justin Mille</u>	Received by: (Signature) <u>[Signature]</u>	Date 4/14/17	Date 4-14-17	Time 1410	Time Time
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date _____	Date _____	Time _____	Time _____
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date _____	Date _____	Time _____	Time _____



**South Jersey  
Water Test, LLC**  
4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwaterest.com  
NJ DEP Certified Lab #08006

## Penns Grove High School

334 Harding Highway  
Carneys Point, NJ 08069

### Results of Lead Analysis

Date & Time Sampled: 04/14/2017 08:55 - 09:42

Date & Time Analyzed: 04/21/2017 14:27 - 17:05

Date & Time Analyzed: 04/24/2017 13:11 - 14:05

Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
HS-WF-1011	7.23	15.5
HS-WF-1012	<2.00	15.5
HS-WF-1009	<2.00	15.5
HS-WF-1010	<2.00	15.5
HS-F-1013	4.12	15.5
HS-F-1014	7.44	15.5
HS-SP-1018	<2.00	15.5
HS-IM-1030	<2.00	15.5
HS-F-1017	7.31	15.5
HS-S-1019	8.60	15.5
HS-F-1015	5.76	15.5
HS-F1016	3.38	15.5
HS-F-1020	3.67	15.5
HS-F-1021	12.4	15.5
HS-F-1022	4.18	15.5
HS-F-1023	5.44	15.5
HS-F-1024	3.40	15.5
HS-WF-1026	<2.00	15.5
HS-WF-1028	4.15	15.5

Units - ug/L = ppb





**South Jersey  
Water Test, LLC**  
4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwatertest.com  
NJ DEP Certified Lab #08006

## Penns Grove High School

334 Harding Highway  
Carneys Point, NJ 08069

### Results of Lead Analysis

Date & Time Sampled: 04/14/2017 08:55 - 09:42

Date & Time Analyzed: 04/21/2017 14:27 - 17:05

Date & Time Analyzed: 04/24/2017 13:11 - 14:05


Sample Location	Sample Result	Action Level
HS-WF-1001	2.56	15.5
HS-WF-1002	4.76	15.5
HS-WF-1003	<2.00	15.5
HS-F-1004	6.95	15.5
HS-F-1006	3.36	15.5
HS-WF-1007	<2.00	15.5
HS-WF-1008	2.30	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.



Mark J. Riether, Laboratory Director

5/5/17

Date



**South Jersey  
Water Test, LLC**  
4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwaterest.com  
NJ DEP Certified Lab #08006

## Penns Grove Carneys Point School District Office

100 Iona Avenue  
Penns Grove, NJ 08069

### Results of Lead Analysis

Date & Time Sampled: 04/14/2017 12:08 - 12:12

Date & Time Analyzed: 04/25/2017 11:36 - 11:47


Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
DO-F-1001	<2.00	15.5
DO-F-1002	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.

  
Mark J. Riether, Laboratory Director

  
Date